

Zeit	Tanktemp	Vorlauf	Rücklauf	Ereignis		
16:20	26	24	32	Pumpe Ein	Datum:	26.12.2009
16:30	35	33	41		Versuch:	02
16:40	42	40	46		Pumpenstufe:	1
16:50	47	44	49		Speichervolumen:	50 Liter
17:00	50	47	51	Holz nachgel.		
17:10	53	49	53		Heizleistung WT ca:	7770 kJ/h
17:20	57	54	60			~ 2,16KW/h
17:30	62	60	67			
17:40	67	62	72		Ofenstart:	16:00
17:50	71	69	74		Messdauer:	170 min.
18:00	72	70	73	Holz nachgel.		
18:10	73	70	73			
18:20	74	72	75			
18:30	75	73	77			
18:40	77	74	78			
18:50	78	75	79			
19:00	78	76	79			

